



M E M O R A N D U M
PROC #22-08

NOTICE TO BIDDERS
CLARIFICATION #1

SENT VIA – E-MAIL

DATE: March 4, 2022
TO: ALL PROSPECTIVE BIDDERS
FROM: Margaret Maddalena, Contract Administrator
RE: **CONTRACT #2086R POT PERM SYSTEM REHABILITATION**

Question #1 Can you advise how you are currently conveying the pot perm from the bottom of the splitter tank to the point of distribution?
I assume you are using two eductors with city water pressure. The discharge point appears to be too far to just use gravity.
Please respond at your earliest convenience.

Response: ***Pot Perm flow from the splitting tank to the discharge point into the system is by gravity flow. Eductors are not used as described in the question.***

cc: Timothy J. Eustace, Executive Director
Maria Alliegro, P.E., LEED AP, Director of Engineering
Paul Serillo, Director of Facilities
Chris Clamser, Engineering Project Manager
William Schaffner, Chief Financial Officer
Mike Broncatello, Comptroller and Chief Investment Officer