



M E M O R A N D U M
PROC #24- 07

NOTICE TO BIDDERS

CLARIFICATION NO. 2

SENT VIA E-MAIL

DATE: February 27, 2024
TO: **POTENTIAL BIDDERS**
FROM: Margaret M. Maddalena, Contract Administrator
RE: **CONTRACT #2127 FILTER REHABILITATION PROJECT**

Question #1: Just want to confirm that we are painting filter walls, troughs and gullets in the filters. Spec doesn't mention gullets.

Response: Yes, painting to include filter walls, troughs, and gullets.

Question #2 Please confirm that we are to use the specified Rotork IQ actuators in the bid.

Response: Yes, all bids to include the specified Rotork actuators. No "or-equals" will be accepted during bidding.

Tim Eustace, Executive Director
Maria Alliegro, P.E., LEED AP, Director of Engineering
Paul Serillo, Director of Facilities
James Stachura, Engineering Project Manager
Jose Pita, Engineering Project Manager