



NOTE:
WANAQUE SOUTH IS A SINGLE LINE 26 KV CUSTOMER

YOU MUST NOTIFY WANAQUE SOUTH 24 HOURS
IN ADVANCE OF ANY OUTAGES FOR MAINTENANCE

THIS IS TO DETERMINE IF THEY ARE REQUIRED TO MAINTAIN
PUMPING AT THIS FACILITY WHEN OUTAGE IS SCHEDULED

THIS DOES NOT APPLY TO EMERGENCY SITUATIONS

NORMAL CUSTOMER NOTIFICATION THROUGH OPERATIONS
STILL APPLY.

SEE CONTACT INFORMATION BELOW

Contact Names/Numbers

Primary Contact:

Edwin Reyes
Cell: 862-666-0147
Email: ereyes@njdwsc.com

Secondary Contact:

Michael Dox
Cell: 862-666-4916
Email: mdox@njdwsc.com

Third Contact and After Hours:

Control Room 24/7
Work: 973-831-6520
Inform Control Room to contact
one of the above mentioned personnel
for outage scheduling.

Security Dispatcher
Work: 973-831-6200
Contact Security Dispatcher to
gain access to site 24/7

NOTE:
26 KV CONTROLS ARE LOCATED
IN THE CONTROL ROOM.
4 KV EQUIPMENT AND CONTROLS
ARE LOCATED IN THE MAIN BUILDING.

LIST OF REVISIONS				CHECKED	PSE&G CONFIDENTIAL	CHANGED BY		STATION - ABBREVIATION	CLASS
NO	DATE	DESCRIPTION	DEPT			TECH	DATE		
				APPROVED	TITLE			WANAQUE SOUTH/CWS	CS
				DRAWN	DATE			FAIRFIELD RD, WAYNE	1 OF 1
				William J. O'Neil	January 31, 2018				



PUBLIC SERVICE ELECTRIC AND GAS COMPANY

STATION - ABBREVIATION				CLASS	
WANAQUE SOUTH/CWS				CS	
ADDRESS		PHONE	DISTRIBUTION DATE	STATION TYPE	SHEET
FAIRFIELD RD, WAYNE		SEE ABOVE	02/02/18	CUST	1 OF 1